

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. LAB/UPJN/011

Dated: 07/03/2026

It is certified that an inspection team headed by Dr. Shamshad Ahmad (Technical Manager) from District Water Testing Laboratory Uttar Pradesh Jal Nigam Bahraich Inspected the RR Aspire Academy Lucknow Road Bahraich 271801 on 07.03.2026 and on the basis of Water Test Report (Attached) bearing no. DWTL202653 Dated 07.03.2026 of District Water Testing Laboratory Uttar Pradesh Jal Nigam Bahraich 271801 Certified that RR Aspire Academy Lucknow Road Bahraich 271801 has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till 06.03.2027

Signature with Seal.....

Name..... Dr. Shamshad Ahmad

Designation..... Technical Manager

Name & Address of the Office / Department:..... District water Testing Laboratory Jal Nigam Bahraich 271801

To,

RR Aspire Academy Lucknow Road
Bahraich
271801

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Drinking Water Sanitary Inspection form for Piped Water Supply

I. Type of facility: Piped water supply

1. General Information:

- a) District: Bahraich
- b) Location: R.R. Aspire Academy
- c) Date of Visit: 07/3/2026

4. Water samples taken? Yes Sample Nos. 1 E.coli/ 100 ml 0

II. Specific diagnosis information for assessment:

(Please indicate at which sample sites the risk was identified)

Survey Checklist			
S.N	Survey Points	No Risk (Yes)	Risk (No)
1	Do any stand posts leak?	Yes	
2	Does surface water collect around any Tap Water?	Yes	
3	Is the area uphill of any Tap Water eroded?	Yes	
4	Are pipes exposed close to any Tap Water?	Yes	
5	Is Human excreta on the ground within 10m of any Tap Water?	Yes	
6	Is there a sewer within 30m of any Tap Water?	Yes	
7	Has there been a disconnuity in the last 10 days at any stand post?	Yes	
8	Are there signs of leaks in the main pipes?	Yes	
9	Do the community report any pipe breaks in the last week?	—	Yes
10	Is the main pipe exposed anywhere in the vicinity?	Yes	
Total Score of Risk			

Risk Score Card			
Risk Hazard	Risk Score	Risk Category Identified	Remark
Low	0-3	Low	
Medium	3-5		
High	6-8		
Very High	9-10		

III. Results and recommendation:

As per Aabac survey & water kept Academy premises are under Low Risk zone & same is safe for drinking purpose.

The following important points of risk were noted: (list nos. 1-10)

As per Aabac Survey Academy are under very Low Risk zone & found area clean & water safe for drinking purpose.

Signature of surveyor: [Signature]

Comments:



Technical Manager
District Level Water Analysis Laboratory
Bahraich-12





Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), BAHRAICH
Plot No. 2763, Jal Nigam Colony, Jail Road Bahraich, Uttar Pradesh-271801



Rept No. 53 Chemical Test: DWTL202653 Date of Rej 07.03.2026 S.No. 53 Page No. 1/1
ULR No. TC13224260000315F

Customer Details: R.R. ASPIRE ACADEMY

Office Name and Address of the Customer: R.R. Aspire Academy Lucknow Road Bahraich

Ref Letter No & Date

Basic details of sample

District	Bahraich	Block	Tejwarpur
Gram Panchayat	Tendawa Basantpur	Village	Tendawa Basantpur
Habitation	Tendawa Basantpur	Location	Lucknow Road Bahraich
Water Source	Tap Water	Sample No.	1
Quantity of Sample	1000 ml	Date of Collection	06.03.2026
Receiving Date	06.03.2026	Sample Collector	Ajay Gaur
Sample Depositer Name	Ajay Gaur		
Analysis Start Date	06.03.2026	Analysis Completion Date	07.03.2026

Environmental Condition

Temperature	25±2°C	Relative Humidity	Upto 70%
-------------	--------	-------------------	----------

Technical Data of Analysis

S.No.	Parameters	Units	Observed Value	Specified Values as		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH	-	7.82	6.5-8.5	6.5-8.5	APHA 23 Edition 4500-H-B-2023 (Electrometric Method)
2	Turbidity	(NTU)	1.34	1	5	IS 3025 (Part 10):2023 (Nephelometric Method)
3	TDS	(mg/L)	90	500	2000	IS 3025 (Part 16):1984:2021 (Gravimetric Method)
4	Chloride	(mg/L)	8.33	250	1000	IS 3025 (Part 32):2019 (Argentometric Method)
5	Total Alkalinity	(mg/L)	59.33	200	600	IS 3025 (Part 23):2023 (Indicator Method)
6	Total Hardness	(mg/L)	41.33	200	600	IS 3025 (Part 21):2019(EDTA Method)
7	Sulphate	(mg/L)	0	200	400	IS 3025(Part 24):2022 (Turbiditic Method)
8	Nitrate	(mg/L)	0	45	45	APHA 23 Edition 4500-NO ₃ -B-2017 (UV-Screening Method)
9	Fluoride	(mg/L)	0	1	1.5	IS 3025(Part 60):2022 (Ion-Selective Electrode)
10	Iron	(mg/L)	0.12	1	1	IS 3025(Part 53):2019 (Phenanthroanthraline Method)
11	Arsenic	(mg/L)	0	0.01	0.01	IS 3025(Part 37):2022 (Spectrophotometric Method)

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing based on the sample sent to the laboratory.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
 - 5.BDL:Below Detection Limit.
 - 6.N.A: Not Applicable.

End of Report

Prepared By

(Shailendra Kumar)
Lab Technician

Authorized Signatory
Technical Manager
District Level Water Analysis Laboratory
(Shamshad Ahmad)
Technical Manager

Laboratory Contact details-Email-eebahraichlab@gmail.com, Mob-8382064686





Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), BAHRAICH
Plot No. 2763, Jal Nigam Colony, Jail Road Bahraich, Uttar Pradesh-271801

Rept No. 36 | Chemical Test: DWLT202653 | Date of Repd 07.03.2026 | S.No. 36 | Page No. 1/1

Customer Details: R.R ASPIRE ACADEMY

Office Name and Address of the Customer: R.R. Aspire Academy Lucknow Road Bahraich

Ref Letter No & Date

Basic details of sample

District	Bahraich	Block	Tejwapur
Gram Panchayat	Tendawa Basantpur	Village	Tendawa Basantpur
Habitation	Tendawa Basantpur	Location	Lucknow Road Bahraich
Water Source	Tap Water	Sample No.	1
Quantity of Sample	1000 ml	Date of Coll	06.03.2026
Receiving Date	06.03.2026	Sample Coll	Ajay Gaur
Sample Depositer Name	Ajay Gaur		
Analysis Start Date	06.03.2026	Analysis Completion Date	07.03.2026

Environmental Condition

Temperature	25±2°C	Relative Humidity	Upto 70%
-------------	--------	-------------------	----------


Technical Data of Analysis


S.No.		Units	Observed Value	Specified Values as per		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Total coliform	No. Per 100 ml	0	Nil	Nil	Membrane filtration Technique
2	E. coli	No. Per 100 ml	0	Nil	Nil	Membrane filtration Technique

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Prepared By


(Shailendra Kumar)
Lab Technician


Authorized Signatory
Technical Manager
District Level Water Analysis Laboratory
Bahraich - U.P.
(Shamsad Ahmad)
Technical Manager

Laboratory Contact details-Email-eebahraichlab@gmail.com, Mob-8382064686

